

**ADDENDUM 001**

**Request for Bid: D1-09-075**

The due date for receipt of bids remains unchanged by this Addendum. Accordingly, the following changes, questions and answers are believed to be of general interest to all potential Offerors. The original solicitation is hereby changed to the extent stated in the department's response to each question on the attached pages of this amendment 001. All other terms and conditions remain unchanged and in full force.

Please sign and return with your bid.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Darrel Butcher, CPPB Senior Procurement Agent
Contractor/Offeror Signature  <hr/> (Signature of person authorized to sign)	Department of Transportation  <i>Darrel Butcher, CPPB</i> (Authorizing Signature)
Date Signed:	Date Signed: 08/26/08

**Addition:**

1. The large 100' dome will be deleted from this quote.
2. The 1' X 1' asphalt wedge around the perimeter of the dome will be deleted from this quote.
3. Drainage to the front of the dome will be dropped from this quote.
4. The inside dimensions for the smaller dome is 40'-3 3/16" average radius, resulting in 5,094 sq.ft.
5. The center of the dome is 10" lower than the perimeter.
6. Allowing for a slight crown in the middle and using an average depth of 5" results in about 156 tons to be used for bidding the inside of the smaller dome.
7. There is to be a 1.5" thick asphalt surface to the south and east of the dome, consisting of 5,000 sq.ft. resulting in 46 tons to be used for bidding the outside surface.

